

Cable, 6mm², L=130mm

Part no. BBA-XLT-6-130
Catalog No. 116902
Alternate Catalog No. BBA-XLT-6-130

Delivery program

Product range		60 mm system
Product range		Accessories
Accessories		Busbar adapters Connection cable
Function		For mounting on flat copper busbars with 60 mm interval between busbar centres
For use with		Suitable for 5 and 10 mm busbar and double T thickness.
Description		Mounted by latching onto de-energized busbar
For use with		BBA...

Design verification as per IEC/EN 61439

Technical data for design verification	I _n	A	32
Rated operational current for specified heat dissipation	P _{vid}	W	0.4
Heat dissipation per pole, current-dependent	P _{vid}	W	1.2
Equipment heat dissipation, current-dependent	P _{vs}	W	0
Static heat dissipation, non-current-dependent	P _{diss}	W	0
Heat dissipation capacity		°C	-25
Operating ambient temperature min.		°C	55
Operating ambient temperature max.			
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Busbar adapter (EC001531)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Busbar trunking system (LV circuitry) / Busbar adapter (low-voltage switching technology) (ecl@ss10.0.1-27-37-03-04 [ACN951011])

Mounting rail armament		None
Type of electric connection		Round conductor
Rated current In	A	0
Min. busbar thickness	mm	0
Max. busbar thickness	mm	0
Width of the adapter	mm	0
Rail width	mm	0
Busbar distance	mm	0