Interlock, mechanical, size 2

Part no. NZM2-XMV Catalog No. 281582

EL-Nummer

4359009

(Norway)





Delivery program

Allows interlocking of 2, 3 or 4 switches, including different construction sized switches, with NZM-XBZ... Bowden cables. Description NZM2(-4) PN2(-4), N(S)2(-4) For use with

Notes

Cannot be combined with NZM...-XTV...-NA door coupling rotary handles.

At least 2 interlock modules are required in order to assemble a mechanical interlock.

Possible combinations and interlock versions → Engineering

Order Bowden cable separately.

Design verification as per IEC/EN 61439

sooigh vormoution to por 120/214 or 100		
EC/EN 61439 design verification		
10.2 Strength of materials and parts		
10.2.2 Corrosion resistance	Meets the product standard's requirements.	
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.	
10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.	
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	Meets the product standard's requirements.	
10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.	
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.	
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.	
10.2.7 Inscriptions	Meets the product standard's requirements.	
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.	
10.4 Clearances and creepage distances	Meets the product standard's requirements.	
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.	
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.	
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.	
10.8 Connections for external conductors	Is the panel builder's responsibility.	
10.9 Insulation properties		
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.	
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.	
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.	
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.	
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must observed.	
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must observed.	
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.	

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Mechanic interlock for switch (EC001044)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Mechanic interlock for switch

(BCI@SS10.0.1-27-37-13-03 [AKN341013])		
Auxiliary contacts, extendable	No	
Number of contacts as normally closed contact	0	

0