

Control circuit plug unit for remote operator

| | |
|-----------------------|------------------|
| Part no. | NZM2-XSVR |
| Catalog No. | 266706 |
| EL-Nummer (Norway) | 4359025 |

Delivery program

| | | |
|--------------------|--|---|
| Product range | | Accessories |
| Accessories | | Auxiliary conductor plug device for plug technology |
| Standard/Approval | | IEC |
| Installation type | | Plug-in units |
| Construction size | | NZM2(-4), N2(-4), NZM3(-4), N3(-4), NZM4(-4), N4(-4) |
| Description | | Auxiliary conductor plug connector for use with plug-in units NZM...-SVE and plug-in socket NZM...-XSVS to disconnect the cables of the remote actuator |
| Number of poles | | 3/4 pole |
| Standard equipment | | Screw connection |

Technical data

| | | | |
|---|------|--|--|
| General | | | |
| Standards | | IEC/EN 60947 | |
| Protection against direct contact | | Finger and back-of-hand proof to VDE 0106 part 100 | |
| Climatic proofing | | Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 | |
| Ambient temperature | | | |
| Ambient temperature, storage | °C | - 40 - + 70 | |
| Operation | °C | -25 - +70 | |
| Mechanical shock resistance (10 ms half-sinusoidal shock) according to IEC 60068-2-27 | g | 20 (half-sinusoidal shock 20 ms) | |
| Safe isolation to EN 61140 | | | |
| between the auxiliary contacts | V AC | 300 | |
| Mounting position | | As required | |
| Direction of incoming supply | | as required | |

Design verification as per IEC/EN 61439

| | | | |
|--|----|--|--|
| Technical data for design verification | | | |
| Operating ambient temperature min. | °C | -25 | |
| Operating ambient temperature max. | °C | 70 | |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | Meets the product standard's requirements. | |
| 10.2.3.1 Verification of thermal stability of enclosures | | Meets the product standard's requirements. | |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | Meets the product standard's requirements. | |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | Meets the product standard's requirements. | |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | Meets the product standard's requirements. | |
| 10.2.5 Lifting | | Does not apply, since the entire switchgear needs to be evaluated. | |
| 10.2.6 Mechanical impact | | Does not apply, since the entire switchgear needs to be evaluated. | |
| 10.2.7 Inscriptions | | Meets the product standard's requirements. | |
| 10.3 Degree of protection of ASSEMBLIES | | Does not apply, since the entire switchgear needs to be evaluated. | |
| 10.4 Clearances and creepage distances | | Meets the product standard's requirements. | |
| 10.5 Protection against electric shock | | Does not apply, since the entire switchgear needs to be evaluated. | |
| 10.6 Incorporation of switching devices and components | | Does not apply, since the entire switchgear needs to be evaluated. | |
| 10.7 Internal electrical circuits and connections | | Is the panel builder's responsibility. | |
| 10.8 Connections for external conductors | | Is the panel builder's responsibility. | |
| 10.9 Insulation properties | | | |

| | | |
|--|--|--|
| 10.9.2 Power-frequency electric strength | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Accessories/spare parts for low-voltage switch technology (EC002498)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Component for low-voltage switch technology (accessories) (ecl@ssi10.0.1-27-37-13-92 [AKN570013])

| | | |
|------------------------------|--|--|
| Type of accessory/spare part | | Auxiliary conductor plug and socket device |
| Accessory | | Yes |
| Spare part | | No |