



Surge arrester Type 2 Requirement class C, UC 350V Pluggable protective modules 4-pole, 3+1 circuit for TN-S and TT systems with remote display

### General data

standard	IEC 61643-11: 2011, EN 61643-11: 2012
product designation	Surge protection device
SPD classification / according to EN 61643-11	
• Test Class I, Type 1	No
• Test Class II, Type 2	Yes
• Test Class III, Type 3	No
number of SPD ports	1
design of the product	Surge arrester
design of pole	3+N/PE
designation of the protective paths	L-N, L-PE, N-PE
accessories	3 x 5SD7468-1 + 1 x 5SD7488-0
fastening method	DIN rail NS 35
material / of the enclosure	PA 6.6 / PBT
size of surge arrester	4 TE
degree of pollution	2
overvoltage category / according to IEC 61010-1	III
protection class IP / at connection all terminals	IP20
shock acceleration	25 gn
vibrational acceleration / at 5 Hz ... 500 Hz / limited to 2,5 h / per axis	5 gn
relative humidity / during operation	5 % ... 95 %
installation altitude / at height above sea level / maximum	2 000 m
width	71.5 mm
height	99 mm
depth	71.5 mm
net weight	398 g

### Electrical data

type of distribution system	TT, TN-S
operating voltage	230 V
continuous operating voltage	
• maximum	350 V
• between N and PE	260 V
• between L and (PE)N	350 V
apparent power consumption / maximum	450 mVA
discharge current	
• at (8/20) $\mu$ s	20 kA
• 1 phase / at (8/20) $\mu$ s	40 kA
follow current extinguishing capability	
• between N and PE	100 A (260 V)
short-circuit rating (SCCR) / at 264 V	25 kA
protection level	

• between L and N	1.6 kV
• between L and PE	1.9 kV
• between N and L	1.4 kV
• between N and PE	1.5 kV
• between PE and N and/or L	1.5 kV
residual voltage	
• between L and (PE)N	
— at rated value of discharge current / maximum	1.6 kV
— at 10 kA / maximum	1.5 kV
— at 5 kA / maximum	1.3 kV
— at 3 kA / maximum	1.1 kV
• between L and PE	
— at rated value of discharge current / maximum	1.9 kV
— at 10 kA / maximum	1.5 kV
— at 5 kA / maximum	1.3 kV
— at 3 kA / maximum	1.2 kV
• between N and PE	
— at rated value of discharge current / maximum	0.4 kV
— at 10 kA / maximum	0.25 kV
— at 5 kA / maximum	0.15 kV
— at 3 kA / maximum	0.1 kV
response value of the surge voltage / at 6 kV / at (1.2/50) $\mu$ s	
• between N and PE	1.5 kV
• response time / between L and (PE)N	25 ns
• response time / between N and PE	100 ns
adjustable response factor / of tripping current	1.6
fuse protection type / at V-shaped connection	80 A AC (gG)
fuse protection type / for T-connector	125 A AC (gG)
insulation resistance (Riso)	1 000 M $\Omega$

#### Connections/ Terminals

type of electrical connection	Screw terminal
stripped length	16 mm
tightening torque	4.3 ... 4.7
stripped length	16 mm
connectable conductor cross-section	
• for finely stranded conductor	1.5 ... 25
• for rigid conductor	1.5 ... 35
• finely stranded	0.5 ... 25
AWG number / as coded connectable conductor cross section	15 ... 2
design of the thread / of the connection screw	M5
signal design	Optical, remote signaling contact

#### Indicator/remote signaling

switching function / of the remote signaling contacts	PDT contact
operating voltage / of the remote signaling contacts / at AC	5 ... 250
operational current / of the remote signaling contacts / at AC	5 mA ... 1 A
connection type of remote signaling contact	M2
connectable conductor cross-section	
• for remote signaling contacts / for rigid conductor	0.14 ... 1.5
• for finely stranded conductor / for remote signaling contacts	0.14 ... 1.5
AWG number / as coded connectable conductor cross section / for remote signaling contacts / minimum	28
AWG number / as coded connectable conductor cross section / for remote signaling contacts / maximum	16
tightening torque / for remote signaling contacts	0.25 N·m
stripped length / of the cable / for remote signaling contacts	7 mm

#### NEMA/UL - Data

type of distribution system	TT, TN-S
TOV behavior	

- at TOV test voltage (L-N)

415 V AC (5 s / withstand mode) / 440 V AC (120 min / safe failure mode)

- at TOV test voltage (N-PE)

1200 V (200 ms / withstand mode)

combustibility class according to UL 94

V-0

## Further information

**Siemens has decided to exit the Russian market (see here).**

<https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business>

**Siemens is working on the renewal of the current EAC certificates.**

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

**Information on the packaging**

<https://support.industry.siemens.com/cs/ww/en/view/109813875>

**Information- and Downloadcenter (Catalogs, Brochures,...)**

<http://www.siemens.com/lowvoltage/catalogs>

**Industry Mall (Online ordering system)**

<https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SD7464-1>

**Service&Support (Manuals, Certificates, Characteristics, FAQs,...)**

<https://support.industry.siemens.com/cs/ww/en/ps/5SD7464-1>

**Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)**

[http://www.automation.siemens.com/bilddb/cax\\_en.aspx?mlfb=5SD7464-1](http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SD7464-1)

**CAx-Online-Generator**

<http://www.siemens.com/cax>

last modified:

8/3/2021 

