Trip block, 1 - 4 A, Motor protection, Connection to SmartWire-DT: no, For use with: PKE12 basic device, PKE32 basic device



Part no. PKE-XTU-4 Catalog No. 121724 Alternate Catalog XTPEXT004B

No.

EL-Nummer 4355186

(Norway)

Delivery program

Delivery program							
Product range					Accessories		
Accessories					Trip blocks		
Basic function					Motor protection Motor protection for heavy	starting duty	
Notes					Also suitable for motors wi	ith efficiency class IE3.	
Setting range							
Overload releases							
Setting range of overload	releases		I _r	A	1 - 4		
Overload release, min.			I _r	Α	1		
Overload release, max.			Ir	Α	4		
Function					With overload release		
Rated uninterrupted current = ra	ted operational current		$I_u = I_e$	Α	4		
Motor rating							
AC-3							
220 V 230 V			P	kW	0.75		
380 V 400 V			P	kW	1.5		
440 V		P	kW	1.5			
500 V			P	kW	2.2		
660 V 690 V			P	kW	3		
For use with					PKE12 basic device PKE32 basic device		
Connection to SmartWire-DT					no		
Motor output/rated motor curren Motor rating	t Rated motor current AC-3						
	220 V	380 V		44	V 04	500 V	660 V
	230 V	400 V					690 V
	240 V	415 V					
P kW	I A	I A		I A		I A	l A
0.18	A 1.04	-		-		-	-
0.25	1.4	-		-		-	-
0.37	2	1.1		1.	02	-	-
0.55	2.7	1.5		1.	39	1.2	-
0.75	3.2	1.9		1.	68	1.5	1.1
1.1	-	2.6		2.	41	2.1	1.5
1.5	-	3.6			28	2.9	2.1
2.2	-	-		-		4	2.9 3.8
3	-	-		-		-	3.8

Technical data

General

donora.			
Standards			IEC/EN 60947, VDE 0660,UL, CSA
Climatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature			
Storage	0	°C	- 40 - 80

Open		°C	-25 - +55
Enclosed		°C	- 25 - 40
Direction of incoming supply			as required
Degree of protection			
Device			IP20
Terminations			IP00
Protection against direct contact when actuated from front (EN 50274)			Finger and back-of-hand proof
Mechanical shock resistance half-sinusoidal shock 10 ms to IEC 60068-2-27		g	25
Altitude		m	Max. 2000
Main conducting paths			
Rated impulse withstand voltage	U_{imp}	V AC	6000
Overvoltage category/pollution degree			III/3
Rated operational voltage	U _e	V AC	690
Rated uninterrupted current = rated operational current	$I_u = I_e$	Α	4
Rated frequency	f	Hz	50/60
Max. operating frequency		Ops/h	60
Motor switching capacity			
AC-3 (up to 690V)		Α	4
AC-4 cycle operation			
Minimum current flow times		ms	500 (Class 5) 700 (Class 10) 900 (Class 15) 1000 (Class 20)
Minimum cut-out periods		ms	500
Note		ms	In AC-4 cycle operation, going below the minimum current flow time can cause overheating of the load (motor). For all combinations with an SWD activation, you need not adhere to the minimum current flow times and minimum cut-out periods.
Trip blocks			
Temperature compensation			
to IEC/EN 60947, VDE 0660		°C	-5 40
Operating range		°C	- 25 55
Setting range of overload releases		$x I_u$	0.25 - 1
short-circuit release			Trip block, fixed: 15.5 x I _r delayed approx. 60 ms

Design verification as per IEC/EN 61439

Short-circuit release tolerance

Phase-failure sensitivity

boolgii vormoudion do por 120/211 or 100			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	4
Heat dissipation per pole, current-dependent	P_{vid}	W	0.2
Equipment heat dissipation, current-dependent	P_{vid}	W	0.6
Static heat dissipation, non-current-dependent	P_{vs}	W	0
Heat dissipation capacity	P _{diss}	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	55
EC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.

IEC/EN 60947-4-1, VDE 0660 Part 102

Does not apply, since the entire switchgear needs to be evaluated.
Meets the product standard's requirements.
Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated.
Is the panel builder's responsibility.
Is the panel builder's responsibility.
Is the panel builder's responsibility.
Is the panel builder's responsibility.
Is the panel builder's responsibility.
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
Is the panel builder's responsibility. The specifications for the switchgear must be observed.
Is the panel builder's responsibility. The specifications for the switchgear must be observed.
The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Tripping bloc for power circuit-breaker (EC000617)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Releasing block for circuit breakers (ecl@ss10.0.1-27-37-04-10 [AKF008013])

[AKI 0000 13])		
Overload release current setting	А	1 - 4
Initial value of the undelayed short-circuit release - setting range	А	15.5
End value adjustment range undelayed short-circuit release	А	62
Rated permanent current lu	А	4
Voltage type for actuating		Self powered
Rated control supply voltage Us at AC 50HZ	V	0 - 0
Rated control supply voltage Us at AC 60HZ	V	0 - 0
Rated control supply voltage Us at DC	V	0 - 0
Number of poles		3
Short-circuit release function		Delayed
With ground fault protection function		No
Type of motor protection		Electronic release