

RC suppressor circuit, 110 - 250 AC V, For use with: DILE...

**Part no.** RCDILE250  
**Catalog No.** 046320  
**Alternate Catalog No.** XTMCXRSB  
**EL-Nummer (Norway)** 4110172

## Delivery program

|   |       |   |                    |
|---|-------|---|--------------------|
| Accessories   |       |   | Suppressor circuit |
| Description   |       |   | RC suppressor      |
| Actuating voltage   | $U_s$ | V | 110 - 250 AC       |
| For use with  |       |   | DILE...            |
| <b>Instructions</b> For AC operation contactors 50 - 60 Hz.<br>The suppressor is fitted as standard in DC operated contactor relays.<br>Note drop-out delay |       |   |                    |

## Design verification as per IEC/EN 61439

|  |            |    |  |
|--|------------|----|--|
| Technical data for design verification   |            |    |  |
| Rated operational current for specified heat dissipation   | $I_n$      | A  | 0  |
| Heat dissipation per pole, current-dependent   | $P_{vid}$  | W  | 0  |
| Equipment heat dissipation, current-dependent  | $P_{vid}$  | W  | 0  |
| Static heat dissipation, non-current-dependent   | $P_{vs}$   | W  | 0  |
| Heat dissipation capacity  | $P_{diss}$ | W  | 0  |
| Operating ambient temperature min.   |            | °C | -25  |
| Operating ambient temperature max.   |            | °C | 50   |
| IEC/EN 61439 design verification   |            |    |  |
| 10.2 Strength of materials and parts   |            |    |  |
| 10.2.2 Corrosion resistance  |            |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |            |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |            |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |            |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |            |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting   |            |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   |            |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  |            |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |            |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   |            |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |            |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   |            |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  |            |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |            |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |            |    |  |
| 10.9.2 Power-frequency electric strength   |            |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |            |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |            |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |            |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating   |            |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility  |            |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function  |            |    | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

## Technical data ETIM 8.0

|   |  |   |            |
|---|--|---|------------|
| Low-voltage industrial components (EG000017) / Surge protection module (EC000683)   |  |   |            |
| Electric engineering, automation, process control engineering / Low-voltage switch technology / Contactor (LV) / Overvoltage limiter (ecl@ss10.0.1-27-37-10-13 [AKF022013]) |  |   |            |
| Function  |  |   | RC-element |
| Rated control supply voltage Us at AC 50HZ  |  | V | 110 - 250  |
| Rated control supply voltage Us at AC 60HZ  |  | V | 110 - 250  |
| Rated control supply voltage Us at DC   |  | V | 0 - 0      |
| Voltage type for actuating  |  |   | AC         |
| With LED indication   |  |   | No         |