



# DECLARATION DE CONFORMITE

## DECLARATION OF CONFORMITY

N° A 8 / 2010

APPAREIL(S) : Obturateur gris RAL7035

SAMPLE DESCRIPTION :

01665

REFERENCE(S) :

REFERENCE(S) :

CARACTERISTIQUES : 18 modules séparables

RATED CHARACTERISTICS :

CET (CES) APPAREIL(S) EST (SONT) CONFORME(S) :

THIS (THESE) DEVICE(S) IS (ARE) IN ACCORDANCE WITH :


A la norme NF EN 60 695.2.11, degré de sévérité 750°C / 30s

Cette déclaration comprend : 1 page

Date de délivrance : 16/02/2010  
Issue date :

*This declaration contains : 1 page*

Responsable du Laboratoire Produits Central  
*Head of test Laboratory*  
Jacques BARBANCEYS



La reproduction de ce document n'est autorisée que sous la forme de fac-similé photographique intégral. Toute reproduction partielle ou toutes insertions de résultats dans un texte d'accompagnement en vue de leur diffusion doit recevoir un accord préalable et formel de LEGRAND.

Ce document résulte d'essais effectués sur un échantillon. Il ne préjuge pas de la conformité des produits fabriqués à l'objet essayé.

*This document shall not be reproduced, except as a complete photographic facsimile. Any partial reproduction, as well as the insertion of any results into an accompanying text for distribution, requires the prior written approval of LEGRAND.*

*This document contains results related only to the items tested. It does not imply the conformity of the whole production to the items tested.*

LEGRAND - 128, Avenue du Mal-de-Lattre-de-Tassigny - F 87045 LIMOGES Cedex - Tél. : (33) 05.55.06.85.92